

 LAN to connect to building or BMS network. CAT-5e or Higher

NOTE:

- A central unmanaged network switch is recommended when three or more Sub-Controllers are being used.
- Reference specific Wire Details for Building Controller and Sub-Controller wiring specifications; AIP-WIRING-01, AIP-WIRING-02

© 2015 Somfy Systems, Inc. All Rights Reserved. This drawing is the property of Somfy Systems, Inc.. The graphics, information and specific ideas in this document are the exclusive property of Somfy Systems, Inc. and must not be made public, copied, or sold. Others seeking permission to reproduce this document, in whole or in part, must obtain permission from Somfy Systems, Inc. in writing.

Network Switch

(Supplied by others)

Tel: 1-800-64-SOMFY Fax: 1-609-495-8165 www.somfysystems.com



Dedicated animeo IP

network connection.

• Do not use with an

active LAN.

П	Date:	09/13/17					Dwg Title:	Project name:
L			Rev	Date	By	Description	animeo IP Building Controller	Technical Library
		8.5" x 11"	-	//	-		w/ 3 Sub-Controllers	Client:
	Scale:	NTS	-	//	-		Wire Detail	Somfy Systems, Inc.
Draw	Sales:	N/A	-	//	-		AIP-WIRING-03	Address: 121 Herrod Boulevard
	Drawn by:	RV	,	//	-			
	Checked by:	PK	-	//	-			Dayton, NJ 08810